

We, Ventilation Control Products Sweden AB,

in accordance with following Directive(s)

2006/95/EC Low Voltage Directive

2004/108/EEC Electromagnetic Compatibility Directive

declare that:

Carbon Monoxide (CO) Detectors

COW-series (wall), COD-series (duct) and COR-series (room)

are in conformity with the applicable requirements of the following documents.

LVD: EN 60950:2000

EMC: EN 61326-1:2006, EN 55011:2009+A1:2010, EN 55022:2006+A1:2007,
EN 6100-4-2:1995+A1:1998+A2:2001, EN 61000-4-3:2006+A1:2008+ISI:2009,
EN 61000-4-4:2004, EN 61000-4-5:2006, EN 61000-4-6:2009
EN 61000-4-11:2004

We hereby declare that equipment named above has been designed to comply with the relevant sections of above referenced specifications. The unit complies with all applicable Essential Requirements of Directives.

Date of issue 16th September 2016

Signed:


Niclas Johansson
CEO / Managing Director

